



SPECIFICATIONS

1895 GALLON SPILL/LEAK CONTAINMENT FOR 1000 GALLON TANKS
 WEIGHT APPROXIMATELY: 14,920 LBS.
 MIN. COMPRESSIVE STRENGTH CONCRETE: 4000 PSI
 REINFORCEMENT: #4 REBAR 12" O.C.E.W. TOP & BOTTOM IN & OUT FLOOR & WALLS
 A SIPHON ARRANGEMENT IS PROVIDED TO DISCHARGE STORM WATER OR RECOVER SPILLED PETROLEUM PRODUCTS.

MODEL SL-1500 CONTAINMENT VESSEL

SCALE: NTS	REV NO.	DATE:
DRAWN BY:		
DATE:		
FILE:		
WIESER CONCRETE		
MODEL SL-1500		
SHEET NO.	0 OF 0	